

TEST REPORT

| CLIENT | Go Green |
|--------|----------|

| TEST METHOD CONDUCTED | ASTM D1335 Standard Test Method for Tuft Bind of Pile Yarn Floor | |
|-----------------------|--|--|
| | Coverings | |

| DESCRIPTION OF TEST SAMPLE | | |
|----------------------------|------------|--|
| IDENTIFICATION | Petmaxx 50 | |
| ROLL NUMBER | G38463B | |
| CONSTRUCTION | Turf | |
| REFERENCE | PO #17807 | |

GENERAL PRINCIPLE

This test method is designed to measure the force required to pull a tuft completely out of a pile floor covering. It is applicable to both cut and looped pile construction. In the event the material contains both cut and loop, only the loop pile is tested.

TEST RESULTS

| 10.6 | 8.5 | 12.7 | 11.4 | 13.2 |
|------|------|------|------|------|
| 12.7 | 9.9 | 10.4 | 12.2 | 11.8 |
| 13.1 | 10.4 | 11.5 | 10.9 | 12.5 |

| AVERAGE TUFT BIND | 11.5 Lbs. |
|-------------------|-----------|

APPROVED BY

NVLAP

714 Glenwood Place

This facility is accredited by the National Voluntary Laboratory Accreditation Program for the specific scope of accreditation under Lab Code 100297. This accreditation does not constitute an endorsement, certification, or approval by NIST or any agency of the United States Government for the product tested. This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory, LLC, shall not be used under any circumstance in advertising to the general public.

